



aitex[®]
research & innovation center

FIRE BEHAVIOUR

Applicant:

ROSCO IBERICA,S.A

Calle del Oro 76 pol ind Sur
ES-28770 COLMENAR VIEJO
Madrid

Is authorized to place the label "Curtains Fire Performance Classification" label according to the 2023AN2125.



CLASSIFICATION OF FIRE BEHAVIOUR: CURTAINS

Nº: 23AN2125



The sample referenced as:

"MUSLIN NATURAL"

MATERIAL:

Ecreu fabric. Composition: 100% cotton, with a weight of 200 g/m².

Has been tested according to the standards EN 1101:1995+A1:2005 and EN 13772:2011, and has been carried out accelerated aging before testing according to ISO 3175-2:2010. The classification according to standard EN 13773:2003 is:

"CLASS 1"

Date of Issue

5st of October 2023

Date: 05/10/2023 14:08:53

Digitally Signed by:GEMA ESTEVE SILVESTRE -

NIF:21666152Z

Celia Dolça
Head of Fire Behaviour lab.